



# CITY OF LODI

## COUNCIL COMMUNICATION

AGENDA TITLE: Specifications and Advertisement for Bids for  
Construction of Berms and Transformer Pad (EUD 92-9)

MEETING DATE: December 3, 1992

SUBMITTED BY: Electric Utility Director

RECOMMENDED ACTION: That the City Council approve the specifications and authorize advertisement for bids for the construction of oil containment berms and transformer pad.

BACKGROUND INFORMATION: The oil containment structures will be installed at McLane Substation around oil-filled electrical equipment to confine an oil spill or leak. Environmental Protection Agency regulations require that equipment storing oil in volumes, as in this case, be equipped with a confinement system that will prevent an oil spill or leak to extend beyond the immediate area of the equipment and not migrate into the soil, the water table or the site drainage system.

The transformer pad is being constructed to accommodate the transformer hank replacement at McLane Substation.

The bid opening date has been set for Tuesday, December 22, 1992.

FUNDING: The estimated cost of this improvement, \$45,000, is included in the Department's 1992-93 fiscal year budget,

  
Henry J. Rice  
Electric Utility Director

Prepared by: Mel Grandi, Electrical Engineer

c: Assist. Electrical Utility Director  
Electric System Supervisor  
Purchasing Officer

APPROVED



THOMAS A. PETERSON



recycled paper